DEPARTMENT OF ENVIRONMENTAL SCIENCES
UNIVERSITY OF KERALA
(Reaccredited by NAAC with 'A++' grade)
Kariavattom Campus – 695 581, Thiruvananthapuram, Kerala
Ph. 91-471- 2308146 hodenvscience@gmail.com
www.keralauniversity.ac.in

15 YEARS OF CELEBRATING THE MAHATMA

Date 7/5/2025

Name & Address : Alan Feldman Public School, Kazhakkoottam
Type of sample : Water sample in a sealed bottle
No. of samples : 1

Water Quality Analysis Report

Sl No.	Parameter (Unit)	S1	Acceptable limit (BIS/WHO)
1	pH	3.10	6.5-8.5
2	TDS (ppm)	175.1	500
3	Conductivity (mS/cm)	327	
4	Turbidity (NTU)	0.3	1
5	Iron (ppm)	0.02	0.3
6	Total Hardness $CaCO_3$ (mg/l)	20	200
7	Total coliforms (MPN/100ml)	0	0

Technical Assistant/ Head of the Department

Athira. S.S

DEPARTMENT OF ENVIRONMENTAL SCIENCES KARIAVATTOM THIRUVANANTHAPURAM

Attested

PRINCIPAL ALAN FELDMAN PUBLIC SCHOOL KAZHAKUTTOM, TVM-695 582

ALAN FELDMAN PUBLIC SCHOOL Kazhakuttom TVM-695 582

Valini P.

SECRETARY ALAN FELDMAN PUBLIC SCHOOL KAZHAKUTTOM-695582

Thiruvananthapuram Municipal Corporation

Pincode: 695033 GST: 32AAAGT0076LIZ9

Phone number 0471-2320821 Email: tvpmcorpn@gmail.com

https://tmc.lsgkerala.gov.in,

Certificate number : 1458553-2025 Date : 18-06-2025

SANITARY CERTIFICATE

This is to certify that the sanitary conditions, waste disposal amenities and hygienic conditions of .....ALAN FELDMAN PUBLIC SCHOOL..... working in building no ...TC2/4218,4219,4219(1)..... of .....CHANTHAVILA WARD..... are good and satisfactory at the time of inspection.

Signature Not Verified
Digitally signed by SASIKUMAR A
Date: 2025.06.18 16:38:53 IST
Reason: KSMART

Health Officer

ALAN FELDMAN PUBLIC SCHOOL Kazhakuttom TVM-695 582

PRINCIPAL
ALAN FELDMAN PUBLIC SCHOOL
KAZHAKUTTOM, TVM-695 582

SECRETARY
AN FELD MAN PUBLIC SCHOOL
KAZHAKUTTOM-695582

This certificate is computer generated and does not require any Seal/Signature in original